

ADAAG/CBC SIGNAGE REQUIREMENTS SUMMARY

ADAAG /CBC	Identification	Sign req'd	4.30.2 Character Proportion	4.30.3 & ANSI 4.28.3 Character Height	4.30.4 Raised Braille Pictogram	4.30.5 Finish & Contrast	4.30.6 Location & Height	4.30.7 CA1117B.5.1.2 Symbols of Access. (Figure #)
4.1.2(7) 4.1.3(16)a	Permanent Room or Space Identification		√		√	√	√	
4.1.2(7) 4.1.3(16)b	Direction or Information about functional spaces.		√	√		√		
#4.28.3	Directories		√	5/8"		√		
4.1.2(7)a 4.6.4	Accessible Parking Spaces, "Van Accessible" below International Symbol where applicable.	Req.						43a/b
4.1.2(7)b	Accessible Passenger Loading Zones.	Req.						43a/b
4.1.2(7)c	Accessible Entrances where not all are accessible.	Req.						43a/b
CA1117B.5.7 4.1.3(8)d 4.1.6(1)h	Directional Signage Route to Accessible Entrance Directional Signage at inaccessible Entrance	Req. Req.	√	√		√		43a/b
*1103.2.4.1.4 +1107.1.4	Accessible Toilets (even if all are accessible) (including portable).	Req.						43a/b
4.1.6(3)ei	Directional signage to Accessible Toilets at inaccessible toilets	Req.	√	√		√		43a/b
CA1103.2.4.2	Directional signage to Accessible Bathing Facilities at inaccessible Bathing Facilities	Req.						
4.1.3(17)a	Directional at inaccessible Telephone where accessible Telephone not visible	Req.	√	√		√		
CA1117B.5.8	Remodeled Building: Sign in Lobby identifying location of accessible toilet rooms and elevators	Req.						
4.1.3(17)b 4.30.7(2)	Volume Control Telephone	Req.						Handset w/ Waves
4.1.3(19)a	Assembly: Fixed Aisle Seats w/removable armrest.	Req.						43a/b
CA1104B.3.4.1	Assembly Ticket Office information regarding availability fixed aisle seats with removable arm rest.	Req.						
4.1.3(19)a	Assembly Ticket Office: Availability of Accessible Seating	Req.						43a/b Optional
4.1.3(19)b 4.30.7(4)	Assembly: Availability of Assistive Listening System.	Req.						43d
CA1104B.3.4.1	Assembly: Similar Phrase "Assistive Listening System Available" in prominent location	Req.						
CA1104.2.7	Area of Refuge identification (illuminated when exit sign illumination required)	Req.	√		√	√	√	43a/b
4.3.11.5	Area of Refuge: Direc. Signage at inaccessible exits, or as otherwise needed to indicate location of Area of Refuge.	Req.						43a/b Optional
4.3.11.5	Instruction of use of Area of Rescue Assistance adjoining 2-way Communication System.	Req.						
CA1103.2.4.2	Exit Stairs: "Exit"	Req.	√	√	√	√	√	
CA1103.2.4.2	Directional Signage at inaccessible stairs and elevators	Req.	√	√		√		
CA1006.16	Exit Stairs: 2 or more stories: Identification sign in landing identifying stair, floor level, level exit discharge and available roof access.	Req.	√	√		√	Center 60" AFF visible w/ door open or closed	
4.10.5	Elevators: Floor designation at Hoistway	Req.	√	2"	√		√	
4.10.12(2)	Elevator Car: Control buttons with Braille and Raised Letters/Numerals; Star @ Main Entry Floor	Req.	√	5/8" Fig.23a	√	√	4.10.12(3) 4.10.12(4)	23a
4.10.14	Elevator: Emergency Communications.	Req.			√		4.10.14	
4.30.7(3)	Text Telephone	Req.						43c
4.30.7(3)	Directional Signage to Text Telephone	Req.	√	√		√		43c
7.3.(3)	Business & Mercantile: Accessible Check-out Aisle	Req.						43a/b
35.163(a)	Prov. info. concerning all services, activities & facilities of public entities (may be signage)	Req.						
10.4.1(2)	Signage for Transportation Facilities, see Transportation Signage Form	Req.	√	√		√		43a/b Optional




Figure 43 International Symbols of Accessibility