

FULL FACILITY REPORT

Building "Four"

SAMPLE REPORT

Facility Number 1004
Address 1125 Washington Avenue
City Denver
State CO
Zip Code 80222
Longitude 100.00
Latitude 32.00
Site Contact John Smith
Telephone (303) 296-0000
Gross Facility Square Feet 6647
Year Built 1934
Surveyor Dan Woosley
Property Type SS
Facility No. 1004
District Eastern Colorado
Property Use Administrative
Owned / Leased O
Standards Used in Survey ADAAG94 / UFAS86
Survey Start Date 1/1/95
Survey Finish Date 1/1/95
Plans Used Fire Safety Plans



Surveyor's Summary This is a public, single story facility on a relatively flat site within a large shopping center. There is "accessible" parking, however it is not fully compliant. Public areas are limited, but need several modifications. Employee areas also need work.

Surveyor's General Notes The main entry door maneuvering clearance should be enlarged to allow better wheelchair access. This work should be coordinated with changes to the parking layout. Notify shopping center mgt. re: curb ramp barriers near entry.

Accommodations Completed The 1934 toilets were enlarged & grab bars installed, however, the "accessible" parking spaces were added which are 12'-0" wide without marked aisles.